



Certificate of Compliance

Certificate: 70058439

Master Contract: 259277

Project: 70058439

Date Issued: February 18, 2016

Issued to: Shandong Lijiu Electrical Machinery
Co.,Ltd.
No.22 Shanhai Road
Rushan City, Shandong 264500
CHINA

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only



Thalia Wang

Issued by: Thalia Wang

PRODUCTS

CLASS 4211 01 - MOTORS AND GENERATORS

CLASS 4211 81 - MOTORS AND GENERATORS - Certified to US Standards

CLASS 4228 01 - MOTORS AND GENERATORS – For Hazardous Locations

CLASS 4228 81 - MOTORS AND GENERATORS – For Hazardous Locations – Certified to US Standards

For details related to rating, size, configuration, etc. reference should be made to the CSA Certification Record or the descriptive report.

Three Phase Squirrel Cage Induction Motor, Inverter Duty Motor, Types BJPE series, 1 to 200 HP, 208-230/460V, 460V or 575V, 60 Hz, Class F insulated, CT 10:1 (6-60Hz), VT 20:1 (3-60Hz), 40 C ambient. Enclosure TEFC. Continuous duty, SF 1.25 max. NEMA frames 143 to 505T, 2, 4 and 6 pole, NEMA design A and B.

Class I, Division 2, Group A, B, C, and D, Temperature Code: T3C for frame size 140 to 320; T3A for frame size 360 to 500.



Certificate: 70058439

Project: 70058439

Master Contract: 259277

Date Issued: February 18, 2016

APPLICABLE REQUIREMENTS

- CSA C22.2 No. 100-14 - Motors and Generators
- UL 1004-1 Second Edition (2015) - Rotating Electrical Machines – General Requirements
- UL 1004-8 Second Edition (2014) - Inverter Duty Motors
- CSA LTR E-013-2005 - Motors and Generators for Use in Class I, Division 2, and Class II, Division 2, Hazardous Locations
- UL 1836 (Issue No. 5) - Outline of Investigation for Electric Motors and Generators for Use in Class I, Division 2, Class I, Zone 2, Class II, Division 2 and Zone 22 Hazardous (Classified) Locations



Supplement to Certificate of Compliance

Certificate: 70058439

Master Contract: 259277

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
70058439	February 18, 2016	Original Certification. Three Phase Squirrel Cage Induction Motor, Inverter Duty Motor, Types BJPE series, 1 to 200 HP, 208-230/460V, 460V or 575V, 60 Hz, Class F insulated, CT 10:1 (6-60Hz), VT 20:1 (3-60Hz), 40 C ambient. Enclosure TEFC. Continuous duty, SF 1.25 max. NEMA frames 143 to 505T, 2, 4 and 6 pole, NEMA design A and B.